

**CITY OF HIALEAH
MILANDER AUDITORIUM
4800 PALM AVENUE
HIALEAH, FLORIDA**


July 26, 2010

TO ALL CONCERNED

The original Contract Documents for the Project entitled: **CITY OF HIALEAH – MILANDER AUDITORIUM – ELECTRICAL, BID NO. 2009/10-3230-00-093** is amended as noted in this Addendum No. 4.

This Addendum No. 4 consists of 1 Typed Page, 0 Sketches 1 Attachment and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:


Oniel E. Toledo – Project Manager
Construction & Maintenance

Date: July 26, 2010

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 4** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah @ (305) 687-2642 and submitted with sealed bids.

ATTACHMENTS:

ATT-1 E-mail from: **Statewide Electrical Services** (dated 07/01/2010)

ANSWERS TO: E-mail from: **Statewide Electrical Services** (dated 07/01/2010)

- The FPL transformer will be located approximately 6' away from the west wall of the generator room. Exact location will be determined by the project supervisor in the field.

ADDENDUM RECEIPT FORM

**CITY OF HIALEAH
MILANDER AUDITORIUM
ELECTRICAL**

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ **FAX NO.** _____

CONTACT NAME _____ **SIGNATURE** _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY OF HIALEAH @ (305) 687-2642

ADDENDUM

SIGNATURE

DATE

4

ARF

Statewide Electrical Services, Inc**REQUEST FOR
INFORMATION**

12905 West Okeechobee Road Bay # 4
Hialeah Gardens, Fl 33018

Phone: (305)-592-6965
Fax: (305)-823-1817

No. 1

TITLE: Request for Information

DATE: 07/01/2010

PROJECT: Miscellaneous
Milander Auditorium Electrical Bid 2009/10-3230-
00-093

TO: Attn: Oniel E. Toledo
City of Hialeah
501 Palm Avenue
Hialeah, Fl 33010
Phone: 305-687-2620 Fax: 305-687-2642

STARTED:

COMPLETED:

REQUIRED:

REQUEST:

Electrical drawings do not show where the FPL transformer will be located.
Is there any known distance between the FPL transformer and the electrical room?
Please advise

ANSWER:

Requested By: Statewide Electrical Services, Inc

Date: 07/01/2010

Signed: _____

Noel Melo

Page 1 of 1

ATT-1